

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1521:105 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: *Ferd Orpano (847) 941-6176 FAX (866) 699-0238

DESIGN: Models MVMP, MVMR, MVMX, MVMP-RM and MVMR-RM Multiple Voice Message Modules.
Refer to listee's data sheet for additional detailed product description and operational consideration.

RATING: Input: 24 VDC at 130 mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as Multiple Voice Message Modules for use only with separately listed compatible Models IRC-3 (CSFM Listing No. 7165-1521:100, 7165-1591:147* and 7170-1591:157*) or FCC (CSFM Listing No. 7165-1591:139*, 7170-1591:158* & 7170-1521:111) fire alarm control units.

NOTE: Formerly 7300-1469:105

XLF: 7300-1591:171*

*Rev. 07-24-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 24, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager